



**LED Retrofitting of Streetlights along Macapagal Boulevard and EDSA
(LED Luminaire – 120w, 220-204v, 60Hz, ta45°C, 0.95 0.55a, ip66
Including Removal & Installation of Streetlights Luminaire)**

**BID BULLETIN NO.1
JULY 26, 2017**

All prospective bidders are hereby informed of the following:

1. The technical specification for the required lumen output of the streetlight should be equal or greater than (\geq) 16,000 lumens
2. The site inspection will be on July 27, 2017 9:30 A.M. with Engr. Rachel Birung Those who will not be able to attend may still set an appointment with Engr. Birung at an appropriate date.
3. Photocell is included in the streetlight LED luminaires delivery.
4. In the event that a foreign currency value is required for a computation, the basis for the conversion into peso shall be the BSP conversion rate that will be published two (2) days prior to the opening of the bid.
5. The color temperature should be cool white (4000+/-400k)

This Bid Bulletin shall form an integral part of the bid documents for the project to be bid.


USEC FRISCO SAN JUAN JR.
BAC Chairman